



WIRING SCHEMATIC FOR CONNECTING DOOR SAFETY KIT LIGHTING TO:

RYTEC SYSTEM 4

The following schematic should work without the need to program the relays on the operator. If required...

- Program the X12 relay to close to ground on Fully Closed. **P.710 = 2**
- Program the X13 relay to close to ground on Fully Open. **P.720 = 0**

